

2513 Reed St. Flatwoods Ky.41139
Meeting location: 2513 Reed St. Flatwoods Kentucky
Meeting Dates and Time: 1st and 3rd Tuesday of each month 7:00PM

Phone: 606-836-9661
CCR Contact: Richard L. Blevins
Phone: 606-836-9661

This report is designed to inform the public about the quality of water and services provided on a daily basis. Our commitment is to provide our customers with a safe, clean, and reliable supply of drinking water. We want to assure that we will continue to monitor, improve, and protect the water system and deliver a high quality product. Water is the most indispensable product in every home and we ask everyone to be conservative and help us in our efforts to protect the water source and the water system.

We purchase water from the cities of Ashland and Russell. An analysis of the water supply for both Ashland(West & South side of town) and Russell(North & East side of town) indicates the susceptibility is moderately high as both have the Ohio River as a surface water source. Within the Kentucky portion of the protection zone alone, there are 536 identified potential contaminant sources. Of these, 302 have a susceptibility rating of high, 206 are rated medium and 28 are rated low. Not all contaminants with a high rating threaten the water supply equally. Oil spills that receive a high rating may float by the intake without noticeable effect. Chemicals that mix with the water present a different type of threat and the intake may be shut down until the danger passes. In all cases the Ohio River Valley Sanitation Commission issues of spills, their location on the river and the speed of the river to all water systems with intakes on the Ohio River. Both of our suppliers are interconnected and Ashland has a 25 million gallon reservoir as a backup water supply. The source water assessment plan (SWAP) is complete and is available for inspection at the FIVCO Area Development District Office in Catlettsburg, Ky.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects may be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and may pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include: Microbial contaminants, such as viruses and bacteria, (sewage plants, septic systems, livestock operations, or wildlife). Inorganic contaminants, such as salts and metals, (naturally occurring or from stormwater runoff, wastewater discharges, oil and gas production, mining, or farming). Pesticides and herbicides, (stormwater runoff, agriculture or residential uses). Organic chemical contaminants, including synthetic and volatile organic chemicals, (by-products of industrial processes and petroleum production, or from gas stations, stormwater runoff, or septic systems). Radioactive contaminants, (naturally occurring or from oil and gas production or mining activities). In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water to provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Some or all of these definitions may be found in this report:

- Maximum Contaminant Level (MCL)** - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology
- Maximum Contaminant Level Goal (MCLG)** - the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety
- Maximum Residual Disinfectant Level (MRDL)** - the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants
- Maximum Residual Disinfectant Level Goal (MRDLG)** - the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants
- Below Detection Levels (BDL)** laboratory analysis indicates that the contaminant is not present -
- Not Applicable (N/A)** does not apply -
- Parts per million (ppm)** - or milligrams per liter, (mg/l). One part per million corresponds to one minute in two years or a single penny in \$10,000
- Parts per billion (ppb)** - or micrograms per liter, (µg/L). One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000
- Parts per trillion (ppt)** - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000
- Parts per quadrillion (ppq)** - one part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000
- Picocuries per liter (pCi/L)** a measure of the radioactivity in water -
- Millirems per year (mrem/yr)** measure of radiation absorbed by the body -
- Million Fibers per Liter (MFL)** a measure of the presence of asbestos fibers that are longer than 10 micrometers -
- Nephelometric Turbidity Unit (NTU)** - a measure of the clarity of water. Turbidity has no health effects. However, turbidity can provide a medium for microbial growth. Turbidity is monitored because it is a good indicator of the effectiveness of the filtration system
- Variations & Exemptions (V&E)** - State or EPA permission not to meet an MCL or a treatment technique under certain conditions
- Action Level (AL)** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system shall follow
- Treatment Technique (TT)** a required process intended to reduce the level of a contaminant in drinking water -

Information About Lead:

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your local public water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Spanish (Español) Este informe contiene información muy importante sobre la calidad de su agua beber. Tradúzcalo o hable con alguien que lo entienda bien.

The data presented in this report are from the most recent testing done in accordance with administrative regulations in 401 KAR Chapter 8. As authorized and approved by EPA, the State has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data in this table, though representative, may be more than one year old. Unless otherwise noted, the report level is the highest level detected. A=Ashland(South & West side of town), R=Russell(North & East side of town), F=Flatwoods.

	Allowable Levels	Source	Highest Single Measurement	Lowest Monthly %	Violation	Likely Source of Turbidity
Turbidity (NTU) TT	No more than 1 NTU*	A=	0.22	100	NO	Soil runoff
* Representative samples of filtered water	Less than 0.3 NTU in 95% monthly samples	R=	0.17	100	NO	

Regulated Contaminant Test Results

Contaminant [code] (units)	MCL	MCLG	Source	Report Level	Range of Detection	Date of Sample	Violation	Likely Source of Contamination
----------------------------	-----	------	--------	--------------	--------------------	----------------	-----------	--------------------------------

Microbiological Contaminants

Total Coliform Bacteria # or % positive samples	1	0	F=	1	N/A	Nov-09	NO	Naturally present in the environment
---	---	---	----	---	-----	--------	----	--------------------------------------

Inorganic Contaminants

Barium [1010] (ppm)	2	2	A=	0.036	0.036 to 0.036	Mar-09	NO	Drilling wastes; metal refineries; erosion of natural deposits
Copper [1022] (ppm) sites exceeding action level 0	AL = 1.3	1.3	F=	0.064 (90 th percentile)	0 to 0.064 to	Sep-09	NO	Corrosion of household plumbing systems
Fluoride [1025] (ppm)	4	4	A= R=	0.827 1.12	0.78 to 1.26 0.9 to 1.12	twice/month 3 times in 09		Water additive which promotes strong teeth
Lead [1030] (ppb) sites exceeding action level 0	AL = 15	0	F=	0 (90 th percentile)	0 to 0.005 to	Sep-09	NO	Corrosion of household plumbing systems
Nickel (ppm) (US EPA remanded MCL in February 1995.)	N/A	N/A	A=	0.008	0.008 to 0.008	Mar-09	NO	N/A
Nitrate [1040] (ppm)	10	10	A= R=	0.786 0.89	0.786 to 0.786 0.89 to 0.89	Feb-09 Apr-09	NO NO	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Nitrite [1041] (ppm)	1	1	A=	0.02	0.02 to 0.02	Mar-05	NO	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

Disinfectants/Disinfection Byproducts and Precursors

Total Organic Carbon (ppm) (report level=lowest avg. range of monthly ratios)	TT*	N/A	A= R=	1.33 1.27	1.05 to 2.02 0.91 to 1.59	N/A	NO NO	Naturally present in environment.
---	-----	-----	-------	-----------	---------------------------	-----	-------	-----------------------------------

*Monthly ratio is the % TOC removal achieved to the % TOC removal required. Annual average of the monthly ratios must be 1.00 or greater for compliance.

Chlorine (ppm)	MRDL = 4	MRDLG = 4	F=	1.24 (highest average)	0.13 to 2.16 to	N/A	NO	Water additive used to control microbes.
HAA (ppb) (all sites) [Haloacetic acids]	60	N/A	A= R=	26 33 (average)	15 to 40 19.7 to 45.9 (range of system sites)	N/A	NO NO	Byproduct of drinking water disinfection
HAA (ppb) (IDSE) [Haloacetic acids]	IDSE (individual distribution system evaluation) is a study to determine future individual sites.				15 to 31 (range of individual sites)	IDSE initiated Aug-08	NO	Byproduct of drinking water disinfection
TTHM (ppb) (IDSE) [total trihalomethanes]	IDSE (individual distribution system evaluation) is a study to determine future individual sites.				21 to 169 (range of individual sites)	IDSE initiated Aug-08	NO	Byproduct of drinking water disinfection
TTHM (ppb) (all sites) [total trihalomethanes]	80	N/A	A= R=	57 71 (average)	18 to 140 23.2 to 133	N/A	NO NO	Byproduct of drinking water disinfection

EPA has not established drinking water standards for unregulated contaminants. There are no MCL's and therefore no violations if found.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing